

FM Zulassung

Pipe Hangers

SPR-Filbow Clamp

O.E.-Single Bossed Clamp

Filbow Clamp

TKN-Girder Clamp with cup point

gültig für

Sprinklerschelle Birnenform

Spinklerschelle mit Rändelmutter

Schraubrohrschelle schwere Ausführung ohne Einlage

Trägerklammer verzinkt

Dieses Dokument der MÜPRO dient nur zur Information und unterliegt nicht dem Änderungsdienst.

Der gesamte Inhalt darf für werbliche oder andere Zwecke nur nach Genehmigung durch die MÜPRO verwendet werden.

Alle Rechte und Änderungen vorbehalten.



Certificate of Compliance

This certificate is issued for the following:

PIPE HANGERS

| <i>Product Designation</i> | <i>Hanger Rod Size, in. (mm)</i> | <i>Component Description</i> | <i>For Nominal Pipe Sizes, in.</i> |
|----------------------------|----------------------------------|------------------------------|--|
| SPR | 3/8 (10) | Filbow Clamp | 3/4 through 4 |
| SPR | 1/2 (12) | " | 5 through 6 |
| O.E. | 3/8 (10) | Single Bossed Clamp | 3/4 through 4 |
| O.E. | 1/2 (12) | " | 3/4 through 6 |
| Filbow Clamp | 3/8 (10) | Filbow Clamp | 3/4, 1, 1 1/4, 1 1/2, 2, 2 1/2, 3, 4 in. 44.5, 50, 57.0, 63.5, 70, 80, 100, 108 mm |
| Filbow Clamp | 1/2 (12) | Filbow Clamp | 5, 6 in. 133, 150, 159, 168.3 mm |
| Filbow Clamp | 5/8 (16) | Filbow Clamp | 8 in. 177.8, 193.7 mm |
| TKN-10 | 3/8 (10) | Girder Clamp with cup point | 3/4 through 4 |
| TK-12 | 1/2 (12) | " | 3/4 through 8 |

Prepared for:

MÜPRO Services GmbH
Hessenstrasse 11
65719 Hofheim-Wallau
Germany



Member of the FM Global Group



Certificate of Compliance

FM Approvals Class: 1951

Approval Identification: 3028091 (May 18, 2007), 3000277 (April 18, 2000), 1W3A9.AH (September 7, 1993), 1W2A4.AH (October 8, 1993), 0P2A3.AH (June 17, 1987)

Said Approval is subject to satisfactory field performance, continuing follow-up Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

For more than 160 years FM Approvals has partnered with business and industry to reduce property losses.

A black and white image of a handwritten signature, which appears to be 'Richard B. Dunne', written in cursive.

Richard B. Dunne
Group Manager –Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062

August 10, 2012

Date



Member of the FM Global Group